



Prüfinstitut für
Abwassertechnik
GmbH

PERFORMANCE RESULTS

Otto Graf GmbH
Carl-Zeiss-Str. 2-6, 79331 Tenningen, Germany

EN 12566-3
Small wastewater treatment systems for up to 50 PT

Small wastewater treatment system one2clean
SBR plant in a polypropylene tank

Nominal organic daily load	0.22	kg BOD ₅ /d
Nominal hydraulic daily load	0.60	m ³ /d
Material	polypropylene	
Treatment efficiency (nominal sequences)	COD	96.2 %
	BOD ₅	98.6 %
	SS	98.3 %
	NH ₄ -N	99.0 %
	N _{tot}	79.1 %
Electrical consumption	0.82	kWh/d

Performance tested by:

PIA – Prüfinstitut für Abwassertechnik GmbH
(PIA GmbH)
Hergenrather Weg 30
D-52074 Aachen

This document replaces neither the declaration
of conformity nor the CE marking.



Notified Body
Nr.: 1739



Certified according to
ISO 9001:2008



Prüfinstitut für Abwassertechnik GmbH
geprüft - tested - testé

Elmar Lancé

February 2014